



# CERTIFICATE OF CONFORMITY

This is to certify that



## MASONS HYDRO Flashing Tape

### Product Description

Masons HYDRO Flashing Tape is a flexible flashing tape system for use around framed joinery openings as a secondary weather resistant barrier.

Size – 50mm x 25m, 75mm x 25m, 100mm x 25m, 150mm x 25m, 200mm x 25m, 150mm x 10m

### Product Purpose or Use

The system is installed into and around the framed joinery opening over the wall underlay and exposed frame to cover both the face and edge of the opening framing. It can also be used at joinery heads to seal flashing upstands to the wall underlay.

### Certificate Holder

#### Masons Plastabrick Ltd

9A Parkhead Place  
Albany, Auckland 0632  
NEW ZEALAND  
Phone: 64 3 455 1502  
www.mpb.co.nz

### Certification Body

#### CertMark International Pty Ltd

T/A CertMark New Zealand  
ABN: 80 111 217 568  
JAS-ANZ Accreditation No. Z4450210AK  
PO Box 321 Tuakau 2121  
www.CertMark.org

### Complies with the New Zealand Building Code :

1. NZBC Clause B2 Durability - Performance B2.3.1 a) - not less than 50 years & B2.3.2.
2. NZBC Clause E2 External Moisture - E2.3.2
3. NZBC Clause F2 Hazardous Building Materials - F2.3.1.

### Subject to the following Conditions & Limitations:

- a. Ensure all surfaces to which MASONS HYDRO Flashing Tape is applied are clean, dry and free of dust.
- b. When applying MASONS HYDRO Flashing Tape to Light Organic Solvent Preservation (LOSP) treated timber, ensure the solvent has been allowed to flash off prior to installing the product. It is suggested that a minimum of one (1) week is allowed for.
- c. MASONS HYDRO Flashing Tape when used, installed and maintained in accordance with the requirements outlined in Hydro technical data sheet (February 2015) and will meet the requirements of Acceptable Solution E2/AS1, Clause 9.1.5 (b) (i).
- d. Only to be installed by a suitable licenced tradesperson.
- e. This certification relates only to the clauses of the NZBC as contained herein. Consequently any clause not included on this certificate are outside the scope of this Certificate. Excluded clauses are to be addressed at an individual project basis.
- f. This certification relates only to the MASONS HYDRO Flashing Tape that is described above and has to be read, considered and used as a whole document — it may be misleading and will be incomplete to be selective.
- g. For further information contact the certificate holder.

  
**John Thorpe**  
CertMark International Pty Ltd

19/02/2015  
Date of Issue

CMA-CM40125  
Certificate Number

- This certificate is issued by an independent certification body accredited by the product certification accreditation body appointed by the Chief Executive of the Ministry of Business, Innovation & Employment (MBIE) under the Building Act 2004. MBIE does not in any way warrant, guarantee, or represent that the building method or product the subject of this certificate conforms to the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. MBIE disclaims, to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages, and costs arising as a result of the use of the building method(s) or product(s) referred to in this certificate
- It is advised to check that this Certificate of Conformity is currently valid and not withdrawn, suspended or superseded by a later issue by referring to the MBIE website, [www.mbie.govt.nz](http://www.mbie.govt.nz)
- This certificate may only be reproduced in its entirety.

